

Treatment ID 20049



Location	Works Required in area Highlighted in purple
Mira Flores Av, Porongurups	<p>*Contact property before works commence. Widen/maintain existing fire access tracks to a minimum of 4m wide where possible, slash/mulch a 1m low fuel boundary on either side, and remove over-hanging vegetation to 5m high.</p>
Treatment Type	Grade track using natural scree,
	All lopping's and materials to be
Size of Area/Length of Track	removed from site or mulched to a fine ground cover.
0.2km	Low fuel boundary includes mulching or removal of previously fallen limbs as well as lopped.